

Status of the ENUBET project

G. Brunetti*

INFN Sezione di Padova

E-mail: giulia.brunetti@pd.infn.it

F. Acerbi^a, G. Ballerini^{b,c}, M. Bonesini^c, C. Brizzolari^{b,c}, M. Calviani^d, S. Carturan^e, M.G. Catanesi^f, S. Cecchini^g, F. Cindolo^g, G. Collazuol^{h,i}, E. Conti^h, F. Dal Corso^h, C. Delogu^{c,j}, G. De Rosa^k, A. Falcone^{h,i}, B. Goddard^d, A. Gola^a, R.A. Intonti^f, C. Jollet^l, V. Kain^d, B. Klicek^m, Y. Kudenkoⁿ, M. Laveder^{h,i}, A. Longhin^{h,i}, P.F. Loverre^{o,p}, L. Ludovici^p, L. Magaletti^f, G. Mandrioli^g, A. Margotti^g, V. Mascagna^{b,c}, N. Mauri^g, A. Mereaglia^q, M. Mezzetto^h, M. Nessi^d, A. Paoloni^r, M. Pari^{h,i}, E. Parozzi^{c,j}, L. Pasqualini^{g,s}, G. Paternoster^a, L. Patrizii^g, C. Piemonte^a, M. Pozzato^g, M. Prest^{b,c}, F. Pupilli^h, E. Radicioni^f, C. Riccio^{k,t}, A.C. Ruggieri^k, C. Scianⁱ, G. Sirri^g, M. Soldani^{b,c}, M. Stipcevic^m, M. Tenti^g, F. Terranova^{c,j}, M. Torti^{c,j}, E. Vallazza^u, F. Velotti^d, M. Vesco^e, L. Votano^r

^aFondazione Bruno Kessler (FBK) and INFN TIFPA, Trento, Italy; ^bPhys. Dep., Università degli studi dell'Insubria, Como, Italy; ^cINFN, Sezione di Milano-Bicocca, Milano, Italy; ^dCERN, Geneva, Switzerland; ^eINFN Laboratori Nazionali di Legnaro, Legnaro (PD), Italy; ^fINFN Sezione di Bari, Bari, Italy; ^gINFN, Sezione di Bologna, Bologna, Italy; ^hINFN Sezione di Padova, Padova, Italy; ⁱPhys. Dep. Università di Padova, Padova, Italy; ^jPhys. Dep. Università di Milano-Bicocca, Milano, Italy; ^kINFN, Sezione di Napoli, Napoli, Italy; ^lIPHC, Université de Strasbourg, CNRS/IN2P3, Strasbourg, France; ^mCenter of Excellence for Advanced Materials and Sensing Devices, Ruder Boskovic Institute, Zagreb, Croatia; ⁿInstitute of Nuclear Research of the Russian Academy of Science, Moscow, Russia; ^oPhys. Dep. Università La Sapienza, Rome, Italy; ^pINFN, Sezione di Roma 1, Rome, Italy; ^qCENBG, Université de Bordeaux, CNRS/IN2P3, 33175 Gradignan, France; ^rINFN, Laboratori Nazionali di Frascati, Frascati (Rome), Italy; ^sPhys. Dep. Università di Bologna, Bologna, Italy; ^tPhys. Dep. Università degli Studi di Napoli Federico II, Napoli, Italy; ^uINFN Sezione di Trieste, Trieste, Italy

The ENUBET project is studying a narrow band neutrino beam where lepton production can be monitored at single particle level in an instrumented decay tunnel and that could provide a 1% measurement of the neutrino flux at source. The three body semi-leptonic decay of kaons monitored by large angle positron production offers a fully controlled ν_e source at the GeV scale for a new generation of short baseline experiments. The ENUBET Collaboration presented at NuFact2018 the first end-to-end simulation of the beamline, the physics performance and the results of the test beam performed on the positron tagger. We reported ENUBET expected fluxes for ν_e and ν_μ .

*The 20th International Workshop on Neutrinos (NuFact2018)
12-18 August 2018
Blacksburg, Virginia*

*Speaker.

1. Monitored neutrino beams: the ENUBET approach

Neutrino cross sections play a crucial role in the oscillation physics of the next generation $\nu_\mu \rightarrow \nu_e$ experiments and are mainly limited by the estimate of the initial flux that relies on the simulation of the beam line and on the limited knowledge of the hadro-production in targets. The ENUBET project [1, 4] addresses this problem by developing a neutrino source based on tagging of large angle positrons from the three body semi-leptonic K_{e3} decays ($K^+ \rightarrow e^+ \pi^0 \nu_e$) in an instrumented decay tunnel. This technique may lead to a reduction of the systematic uncertainties on the knowledge of the initial neutrino flux to $\sim 1\%$, i.e. one order of magnitude lower than at present neutrino beams.

In the present ENUBET configuration the decay tunnel to be instrumented consists in an hollow cylinder with a length of 40 m and a 1 m radius. The maximum expected rate at the detector (positron tagger) is about 200 kHz/cm² and e/π separation better than 3% is needed to reject the pion background due to beam halo and to other kaon decay modes. This separation is achieved by means of longitudinally segmented calorimeters. Photons produced by π^0 decays are vetoed by plastic scintillator pads located just below the calorimeter. The photon veto also provides a precise timing of the positrons. These requirements constrain the detector technology, that must be based on radiation hard components with O(10 ns) recovery time and 10 cm² granularity.

2. The transfer line

The ENUBET transfer line has to focus and transport a collimated beam of pions and kaons with high efficiency, limited losses by decays and low beam-induced background. The optimization of the optics is performed with TRANSPORT [2] using a reference momentum of 8.5 GeV/c and a momentum bite of 10% while particle transport and interactions in the beamline are simulated with G4beamline [3]. Two options have been investigated: a horn-based beamline employing a pulsed horn between the target and the transport line and a static system where the transport and focusing line is implemented directly after the target and the field in the focussing or bending elements do not vary in time.

Though the horn-based solution would provide higher yields at the decay tunnel one has to consider the horn pulse limit (< 10 ms) and the tagger rate limit that would be reached with $\sim 10^{12}$ protons on target (POT) per spill. The static transfer line on the other hand only requires a single slow extraction and is beneficial in terms of pile-up effects in the tagger. Preliminary results obtained with the static option look very promising: by using a triplet-dipole-triplet scheme we obtain hadronic rates at the decay tunnel entrance that are 4 times better than the first estimate presented in [1]. Moreover, this solution would also offer the possibility of event-by-event tagging by coincidences between ν_e at a far detector and e^+ at the tagger. In Tab. 1 our expected rates for the two configurations are reported. A schematic view of the static transfer line is shown in Fig. 1.

3. The positron tagger and detectors R&D

The reference design of the positron tagger is based on calorimetric units (UCM) made of five, 15 mm thick, iron layers, interleaved with 5 mm thick plastic scintillator tiles. The total thickness

Focusing	π^+ /POT [10^{-3}]	K^+ /POT [10^{-3}]	Extraction Length	Factor w.r.t. [1]
Horn-based	77	7.9	2 ms	$\times 2$
Static	19	1.4	2 s	$\times 4$

Table 1: Expected rates of π^+ and K^+ in $[6.5 \div 10.5 \text{ GeV}/c]$ range at the decay tunnel entrance for the two possible focusing schemes. The improvement factor in kaon transport with respect to [1] is shown in the last column.




Figure 1: Schematics of the static line design.

of the UCM module corresponds to $4.3 X_0$ and its transverse size is $3 \times 3 \text{ cm}^2$. The readout is performed through WLS fibers coupled to silicon photomultipliers (SiPM). Doublets of plastic scintillator tiles ($3 \times 3 \text{ cm}^2$ surface and 5 mm thickness for $\sim 0.02 X_0$) provide e^+/π^0 separation. This photon-veto also provides the absolute time of the event (t_0 -layer). During 2016-2018 tests in four two-week slots of data taking were performed to validate prototypes for the t_0 -layer and the calorimeters both in shashlik and lateral readout modes [5, 6, 7, 8]. At present, both options fulfill the requirements of ENUBET and a final decision will be taken in 2019 based on the result of final tests in 2018.

During the lifetime of the experiment the SiPM will integrate a neutron fluence of $O(10^{11})$ 1 MeV-equivalent neutrons/cm². A dedicated irradiation campaign was performed in 2017 using the CN accelerator at the INFN-LNL laboratories where neutron fluences up to 10^{12} n/cm^2 were integrated. UCM prototypes read out by the neutron irradiated SiPM boards were then tested at the CERN-PS T9 beamline. The calorimetric performance of the detector were not compromised by irradiation. During the beam test at CERN we were also able to perform the measurement of the photon-veto time resolution and we validated the 1-mip/2-mip separation capability using photon conversion from π^0 gammas.

4. The ENUBET narrow band beam

Assuming 4.5×10^{19} POT at the CERN-SPS, about 1.13×10^6 ν_μ -CC and 1.4×10^4 ν_e -CC interactions will be observed at a neutrino detector (500 t fiducial mass) located 50 m from the end of the tunnel. A narrow band beam such as ENUBET not only provides a beam with a precisely measured flux but also a measurement of the neutrino energy that does not rely on the reconstruction of final state particles. This feature (“narrow-band off-axis technique”) results from the narrow momentum bandwidth of the beam and the finite transverse dimension of the neutrino detector. The energy measurement exploits the correlation between the energy of the neutrino interacting in the detector and the radial distance (R) of the interaction vertex from the beam axis. The centroid of the

distribution of the vertices of interacting neutrinos could be determined very well in a short time with a high-granularity detector like a LAr TPC (cm level precision). The radial distance could then be measured on an event by event basis with an extremely good resolution. The incoming neutrino energy can be determined with a precision given by the pion peak width of the spectrum at a fixed R. It ranges from 7% at 3.5 GeV to 22% at 0.8 GeV.

Acknowledgments

This project has received funding from the European Research Council (ERC) under the European Unions Horizon 2020 research and innovation programme (grant agreement N. 681647).

References

- [1] A. Longhin, L. Ludovici, F. Terranova, *Eur. Phys. J. C* **75** (2015) 155
- [2] K. L. Brown *et al.*, TRANSPORT, A Computer Program for Designing Charged Particle Beam Transport Systems, 1983, CERN-80-04
- [3] T. J. Roberts and D. M. Kaplan, G4beamline simulation program for matter-dominated beamlines, 2007 IEEE Particle Accelerator Conference (PAC), Albuquerque, NM, (2007) 3468-3470
- [4] A. Berra *et al.*, CERN-SPSC-2016-036, SPSC-EOI-014, Geneva, 2014.
- [5] Documentation available at <http://enubet.pd.infn.it/>.
- [6] A. Berra *et al.*, *Nucl. Instrum. Meth. A* **830** (2016) 345.
- [7] A. Berra *et al.*, *IEEE Trans. Nucl. Sci.* **64** (2017) 1056.
- [8] G. Ballerini *et al.*, *JINST* **13** (2018) P01028.