

Fukushima Daiichi Nuclear Power Station : Results of Nuclide Analysis of Sub-drain

Reference

Data summarized on April 28th)

Place of sampling	Sub-drain of Unit1, Fukushima Daiichi	Sub-drain of Unit2, Fukushima Daiichi	Sub-drain of Unit3, Fukushima Daiichi	Sub-drain of Unit4, Fukushima Daiichi	Sub-drain of Unit5, Fukushima Daiichi	Sub-drain of Unit6, Fukushima Daiichi	Deep well, Fukushima Daiichi
Time and Date of Sample Collection	10:20 April 27th, 2011	10:10 April 27th, 2011	10:00 April 27th, 2011	11:56 April 27th, 2011	10:50 April 27th, 2011	10:40 April 27th, 2011	8:39 April 27th, 2011
Detected Nuclides (Half-life)	Density of Sample (Bq/cm <sup>3</sup> )						
I-131 (about 8 days)	5.5E+01	3.9E+02	2.8E+01	4.9E-02	4.1E-02	3.1E-01	ND
Cs-134 (about 2 years)	5.3E+01	2.1E+01	2.8E+00	1.2E-01	6.6E-02	2.4E-01	ND
Cs-137 (about 30 years)	6.2E+01	2.4E+01	3.0E+00	1.3E-01	7.6E-02	2.6E-01	ND

. E - means . × 1 0 .

Data of other nuclides are under evaluation.