

MODIFICATION OF AA-SEPTUM VACUUM CHAMBER

M. Zanolli

The AA short-term improvement programme¹⁾ foresees the replacement of the septum vacuum chamber to have better beam acceptance at injection.

The original design lets the beam just pass by at the downstream end of SM1 with the theoretical beam characteristics then available.

Later calculations²⁾ with revised AA-parameters show that a larger kick for injection is required to clear this point ($\Delta r = 5 \text{ mm}$) and that there would be a further restriction on the other side of the chamber at the upstream end of SM1.

A design study was made and it is proposed to cut-off the symmetrically positioned arms upstream and downstream of the main part of the vacuum chamber, and to replace them by a slightly different arrangement (Fig. 1).

In this way a space of 2.5 mm is gained on either side of the septum magnet (2 mm due to tube displacement and 0.5 mm due to a reduction of wall-thickness) with none or perhaps negligible septum magnet modifications (Fig. 2), thereby reducing the required extra kicker voltage.

Although of less importance, the vertical aperture will also be increased up to the limit of the space available.

Drawing A-43-5006-4 shows the cross-section of the built-in vacuum chamber arms, while drawing A-43-5032-4 shows the proposed ones.

Strength calculations³⁾ indicate that the new section will withstand the loadings.

Fig. 3 illustrates the positions of the nodal points considered and the deflection of the rectangular tube, while Tables 1 to 3 give the values of deflection, stresses and moments respectively at these points.

Two identical sub-assemblies (tubes, flanges and cover) will be prepared and vacuum-tested after controlling, cleaning and vacuum-firing.

During the shut-down in winter 1982 the septum vacuum chamber will be taken out of the ring, both ends accurately machined-off and the remaining part cleaned. Then the two sub-assemblies will be accurately positionned and welded into place. Cleaning of the whole chamber or only partially, if necessary, and final vacuum tests will conclude the operation.

After installation in the ring more care has to be taken when mounting the septum magnet around it.

It is believed that this proposal represents the best and most economical solution with the actual septum magnets.

Fabrication within the restricted time schedule should cause no problems. Manufacture could start in September. The new rectangular tubes are already available.

References

- 1) E.J.N. Wilson handed out a note under the heading "Consolidation Hardware 1982/1983" at a meeting on 19.1.1982.
- 2) B. Autin, A. Poncet and R. Sherwood have since calculated again and independently the beam position and its profile under different conditions.
- 3) H. Stucki made these calculations with the SAFE-SHELL program.

Distribution

B. Autin	S.E. Milner
E. Boltezar	P. Pearce
J.C. Brunet	A. Poncet
B. Jenny	J.C. Schnuriger
E. Jones	R. Sherwood
C. Johnson	H. Stucki
H. Koziol	B. Williams
	E.J.N. Wilson

For information

R. Billinge
D. Fiander
P.L. Riboni
S. van der Meer







FIG. 1 : MODIFICATION OF SEPTUM VACUUM CHAMBER
PROPOSAL

FIG. 2: VACUUM CHAMBERS IN SEPTUM MAGNET



Modifications.....

Ce dessin ne peut être utilisé à des fins commerciales sans autorisation écrite
This drawing may not be used for commercial purposes without written authorization



pour 1000
de long

First angle projection
Projection européenne

Ensemble Assembly	A-43-5005-0	S/ensemble S/assembly	A-43-5007-0	Nom-Name	Date	Issue
A A	Vacuum Chamber			Echelle Scale	Dessiné Contrôlé	REGAT C-4-78
	Vacuum for Septum Rectangular Tube			1:1		
						A
						B
						C
ORGANISATION EUROPÉENNE POUR LA RECHERCHE NUCLÉAIRE EUROPEAN ORGANIZATION FOR NUCLEAR RESEARCH	CERN LAB 1	CH-1211 GENÈVE 23	ISR	A-43-5006-4		

INDICE	DATE	NOM	MODIFICATION
DIMENSION	> 1	> 30	> 120
USAGE	± 0.2	± 0.3	± 0.8
MÉCANO-SOUDURE	± 0.5	± 0.8	± 1

TOLERANCES GÉNÉRALES	
INDICE	DATE

DESSIN, RUGOSITÉ, TOLÉRANCES SELON NORMES ISO

Ce dessin ne peut être utilisé à des fins commerciales sans autorisation écrite.
This drawing may not be used for commercial purposes without written authorisation.

INDICE		DATE		NOM		MODIFICATION			
1									
<p>CE DESSIN REPRÉSENTE UNE PARTIE DU Système à l'Accélérateur à Proton (p = 10^{-10} Torr). Les soudures doivent être faites par l'arc de fil métallique (tous les deux types de fil sont admissibles) sans dégagement de gaz. La température devrait être de 250°C. Un détecteur de fuite doit être capable de déceler une fuite de 10^{-10} cm³/sec. (équivalent à 1000 fuites/min.). Aucune soudure ne sera acceptée. Tous les dégagements doivent être évités et enlevés.</p> <p>Ne pas égraver les soudures.</p> <p>Inscrire le numéro de dessin dans la zone hachurée.</p>									
<p>This drawing represents a part of the vacuum chamber system of the Antiproton Accumulator (p = 10^{-10} Torr). All welds must be made by either TIG or electron beam welding; in all cases 100% penetration welds are necessary. All assembly parts must be leak checked with a spectrometer having a detection limit at 2×10^{-10} cm³/sec. of helium (AES 2, 1, 1963). No leak should be detected. All parts must be cleaned before leak checking.</p> <p>Do not grind the welds.</p> <p>Inscribe drawing No. shaded area with an electric pencil.</p>									
2		SHEET 1.5 THICK		ST.ST.316LN		166 * 1300		44.59.32.515.8	
NOMBRE PAR UNITÉ	DESCRIPTION	POS.	MATIÈRE	COTES BRUTES			FOURNISSEURS No SCEM		
				S. ENSEMBLE					
ENSEMBLE					NOM		DATE		
AA - VACUUM SYSTEM					ÉCHELLE SCALE	DESSINÉ par	7.6.82		
RECTANGULAR TUBE FOR SEPTUM VACUUM CHAM.									
 ORGANISATION EUROPÉENNE POUR LA RECHERCHE NUCLÉAIRE EUROPEAN ORGANIZATION FOR NUCLEAR RESEARCH CERN-DIV: PS		TEL 0221 63 61 11 TELEX GENEVE 236 93			1:1	CONTÔLÉ	REPLACE		
									REPLACE PAR
							RÉDUCTION		
A.43.5032.4								INDICE	




FIG. 3: DEFLECTION OF VACUUM CHAMBER

NODAL POINT R=DISPLACEMENT Z=DISPLACEMENT		ROTATION	LOADING CONDITION 1
1	54285859E-01	0.	
2	54532466E-01	-30550800E+04	226265551E-03
3	5254459E-01	-61101568E-04	43607611E-03
4	5398361E-01	-91652275E-04	61297686E-03
5	57875040E-01	-12220290E-03	74051286E-03
6	59559713E-01	-1520275341E-03	802220918E-03
7	61291946E-01	-1830382E-03	78167091E-03
8	62875649E-01	-213385412E-03	66238312E-03
9	64079084E-01	-24440432E-03	42791090E-03
10	64634857E-01	-27495417E-03	61799329E-03
11	644205924E-01	-3050461E-03	45240652E-03
12	620255588E-01	-33665481E-03	11311616E-03
13	58207499E-01	-366660518E-03	199009207E-03
14	53785655E-01	-39215583E-03	30481389E-03
15	45844403E-01	-42770691E-03	43192710E-02
16	34902437E-01	-45825860E-03	58207720E-02
17	32085137E-01	-61257322E-03	61783279E-02
18	29130900E-01	-10871785E-02	65458701E-02
19	26073486E-01	-19130910E-02	69216593E-02
20	22952552E-01	-311772036E-02	73038664E-02
21	19813243E-01	-47236951E-02	76905920E-02
22	167055669E-01	-67480045E-02	80798874E-02
23	13683605E-01	-92008907E-02	84697758E-02
24	10894501E-01	-12085127E-01	88582739E-02
25	81273485E-02	-15395355E-01	92434135E-02
26	57119218E-02	-191176335E-01	96232035E-02
27	3617337E-02	-23229199E-01	99959590E-02
28	19006429E-02	-27698449E-01	10359678E-01
29	61545688E-02	-32485172E-01	10712749E-01
30	18942981E-03	-37541007E-01	11053584E-01
31	47138009E-03	-42810124E-01	11380734E-01
32	44657056E-03	-69508904E-01	12721425E-01
33	42176104E-03	-98820447E-01	13747574E-01
34	39695152E-03	-13006876E+00	14476655E-01
35	37214201E-03	-166661648E+00	14926142E-01
36	34733305E-03	-199666488E+00	15113510E-01
37	32523030E-03	-22925384E+00	150562335E-01
38	299771351E-03	-226226190E+00	14771700E-01
39	272904402E-03	-294440619E+00	14277650E-01
40	24809454E-03	-322504250E+00	13591290E-01
41	22328506E-03	-35436524E+00	12730185E-01
42	19847558E-03	-38140743E+00	11711809E-01
43	17366612E-03	-40604075E+00	10553636E-01
44	14885665E-03	-42797548E+00	92731421E-02
45	12404720E-03	-44696055E+00	78878010E-02
46	99237748E-04	-46278349E+00	64150874E-02
47	74428303E-04	-47527048E+00	48724760E-02
48	49518863E-04	-48428633E+00	32774412E-02
49	24809429E-04	-48973447E+00	16474577E-02
50	0.	-49155695E+00	0.

TABLE 1: DEFLECTION VALUES

TABLE 2: STRESSES OF VACUUM CHAMBER

TABLE 3 : MOMENT VALUES OF VACUUM CHAMBER